

















## GENERAL NOTES


THESE DRAWINGS ARE SUBJECT TO APPROVAL BY THE BUILDING DEPARTMENT, FIRE MARSHAL, UTILITY COMPANY AND OTHER AUTHORITIES HAVING JURISDICTION (AHJ). BY THE ACT OF SUBMITTING A BID PROPOSAL FOR WORK, THE CONTRACTOR INDICATES THAT HE OR SHE HAS REVIEWED THE PLANS THOROUGHLY AND ACCEPTED FULL RESPONSIBILITY OF PLAN CORRECTIONS AND ASSOCIATED CONSTRUCTION COSTS REQUIRED BY AHJ.

ELECTRICIAN TO PROVIDE STAINLESS STEEL COVER PLATES FOR ALL LOW VOLTAGE OUTLETS.

IF PROVIDED UNDER SLAB ALL UNDERGROUND CONDUIT SHALL BE  
12" BELOW FINISHED GRADE.

NOTE: ALL DIMENSIONS GIVEN ARE TO DEVICE CENTERLINES. CONTRACTOR TO COORDINATE ALL INSTALLATIONS

POWER DISTRIBUTION		RECEPTACLES & COMMUNICATIONS OUTLETS	
	SINGLE-POLE SWITCH, MANUAL MOTOR STARTER		DUPLEX CONVENIENCE OUTLET, 20A, 125V, MTD @ 18" A.F.F. U.N.O.
	J-BOX (WITH FLEX CONNECTION TO EQUIPMENT.)		SIMPLEX CONVENIENCE OUTLET, 20A, 125V, MTD @ 18" A.F.F. U.N.O.
	DISCONNECT SWITCH, WITH RATING AS SHOWN ON PLANS		ISOLATED GROUND SIMPLEX CONVENIENCE OUTLET (ORANGE), 20A, 125V., MTD @ 18" A.F.F.
	COMBINATION DISCONNECT SWITCH / MOTOR STARTER FURNISHED BY ELECTRICAL CONTRACTOR.		DUPLEX CONVENIENCE OUTLET MOUNTED 3" ABOVE COUNTERTOP BACKSPLASH OR APPROXIMATELY 44" A.F.F.
	BRANCH CIRCUITRY CONCEALED IN WALL OR CEILING WITH ADDITIONAL #12 INSULATED GND. U.N.O. HACHURES INDICATE NUMBER OF CURRENT CARRYING CONDUCTORS. 'X' INDICATES ADDITIONAL INSULATED, ISOLATED GROUND CONDUCTORS.		GFCI DUPLEX CONVENIENCE OUTLET, 20A, 125V, 5 mA TRIP, MTD @ 18" A.F.F. U.N.O.
	BRANCH CIRCUITRY HOMERUN TO PANEL AS NOTED ON PLANS		GFCI DUPLEX CONVENIENCE OUTLET MOUNTED 3" ABOVE COUNTERTOP BACKSPLASH OR APPROXIMATELY 44" A.F.F.
	INDICATES EXTERIOR UNDERGROUND WIRE RUNS.		TELEPHONE OUTLET. PROVIDE FLUSH J-BOX @ 18" AFF U.N.O W/ 1" CONDUIT W/ PULL WIRE TO MANAGER'S STATION. W/ SUBSCRIPT INDICATES WALL PHONE AT 54" AFF.
LIGHTING & LIGHTING CONTROLS			DATA OUTLET. PROVIDE FLUSH J-BOX @ 18" A.F.F. U.N.O W/ 1" CONDUIT WITH PULL WIRE TO MANAGER'S STATION.
	LIGHTING FIXTURE. SUBSCRIPT LETTER DENOTES FIXTURE TYPE AS DESCRIBED IN LIGHT FIXTURE SCHEDULE.		COMBINATION TEL/DATA OUTLET. PROVIDE FLUSH J-BOX @ 18" AFF U.N.O W/ 1" CONDUIT WITH PULL WIRE TO MANAGER'S STATION.
	SINGLE-POLE SWITCH @ 44" A.F.F. U.N.O. LOWER CASE LETTER DENOTES FIXTURE CONTROL. 300V. 20A.		T.V. SYSTEM DATA OUTLET. PROVIDE FLUSH J-BOX @ 18" A.F.F. U.N.O W/ 1" CONDUIT WITH PULL WIRE TO MANAGER'S STATION. WHEN SHOWN ADJACENT RECEPTACLE, MOUNT AT RECEPTACLE HEIGHT. REFER TO RECEPTACLE FOR MOUNTING HEIGHT.
	LEVITON Renoir II WALLBOX DIMMER - SINGLE-POLE SWITCH @ 44" A.F.F. U.N.O. LOWER CASE LETTER DENOTES FIXTURE CONTROL. 120V. BALLAST 0-10V		SPECIAL PURPOSE RECEPTACLE MTD. @ 18" A.F.F. U.N.O. AMPERAGE AND PHASE AS NOTED ON PLANS, NEMA CONFIGURATION AS REQ'D.
	OCCUPANCY SENSOR SWITCH WITH OFF CONTROL, AND ADJUSTABLE SETTINGS FOR TIME OFF DELAY, FOOTCANDLE LEVEL, AND MASKING. WATTSTOPPER OR EQUAL, MOUNT AT 44" A.F.F. U.N.O. USE PW-100 FOR OFFICES/CONF/ETC.		ISOLATED GROUND DUPLEX CONVENIENCE OUTLET (ORANGE), 20A, 125V. MTD @ 18" A.F.F.
	LEVITON PROVOLT 05C20-MDW DIMMING DAYLIGHT SENSOR FOR SIDELIT DAYLIGHTING ZONES. LOCATE AND INSTALL PER MANUFACTURER'S INSTRUCTIONS. ALL CONTROLS SHALL COMPLY WITH LOGICAL ENERGY CODE REQUIREMENTS. PROVIDE LOCAL MANUAL SWITCH AS SHOWN IN THE LIGHTING PLAN FOR ON / OFF CONTROL		DOUBLE DUPLEX CONVENIENCE OUTLETS UNDER COMMON COVER 20A, 125V.
			ISOLATED DOUBLE DUPLEX CONVENIENCE OUTLETS (ORANGE) 20A, 125V.
	INTERIOR LIGHTING SHUT DOWN OVERRIDE. 20 AMP 60-MINUTE INDOOR IN-WALL SPRING WOUND COUNTDOWN TIMER, WHITE BY INTERMATIC.		SPEAKER
ABBREVIATIONS		FIRE ALARM	
A	AMPERES		MANUAL PULL STATION WITH KEYED RESET. MOUNT UNIT AT 44" A.F.F. ALIGN WITH LIGHT SWITCH IF APPLICABLE.
AL	ALUMINUM		XENON STROBE UNIT MOUNTED AT 80" A.F.F. OR 6" BELOW CEILING (WHICHEVER IS LOWER). MUST MEET OR EXCEED A.D.A. REQUIREMENTS.
A.F.F.	ABOVE FINISHED FLOOR		COMBINATION XENON STROBE AND HORN/CHIME UNIT MOUNTED AT 80" A.F.F. OR 6" BELOW CEILING (WHICHEVER IS LOWER). UNIT MUST MEET OR EXCEED A.D.A. REQUIREMENTS.
A.F.G.	ABOVE FINISHED GRADE		FIRE ALARM CONTROL PANEL, MOUNT TOP OF UNIT AT 72" A.F.F.
C	CONDUIT		FIRE ALARM ANNUNCIATION PANEL, MOUNT TOP OF UNIT AT 72" A.F.F.
C/B	CIRCUIT BREAKER		PHOTO ELECTRIC TYPE SMOKE DETECTOR.
CU.	COPPER		DUCT MOUNTED PHOTO ELECTRIC SMOKE DETECTOR.
DISC.	DISCONNECT		RATE OF RISE HEAT DETECTOR.
F	FUSE		
G.F.I.	GROUND FAULT CURRENT INTERRUPTER		
GND.	GROUND		
H.P.	HORSE POWER		
k	1000		
E.C.	ELECTRICAL CONTRACTOR		
G.C.	GENERAL CONTRACTOR		



All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

ISSUE DATE:


CHECK SET	04-20-23
BID/PERMIT SET	06-01-23

DRAWN BY: BDG

PANDA PROJECT #: D24958

PANDA STORE #: TBD

ARCH PROJECT #: 239201



PANDA HOME 2600  
450 Kannapolis Parkway  
Concord, NC 28027

E-000

PANDA HOME 2600 R3